

Nuraply Everguard TPO Concrete Substrate Readiness Checksheet

Project Name: _____
Form Completed by: _____
Company: _____
Area ready: _____
Applicator _____
Fax Number: _____

- Structure complies to the New Zealand Building Code and concrete complies with NZS 3101 (2006)
- Concrete cured with curing membranes removed. Concrete substrate contains less than 5% moisture content.
- Surface smooth and clean with falls as per plan.
- Cavities and cracks filled with Nurapatch, flushed off and cured.
- Concrete surface firm with any soft concrete or laitance removed.
- Ponding areas removed.
- Roof drains and overflow recesses formed to fit rebated outlets.
- If terminating into a chase, pre-form the chase and ensure it's straight and 20mm deep.
- Plinths formed for any exterior ventilation, solar panels or fixtures.
- Construction joints incorporated in slab as per designers specification.
- Substrate clean, firm and suitable condition for laying the Nuralite systems.

When substrate ready complete this form and fax to the Nuralite applicator

Notes

Signed by head contractor

Date: