

**Metal Tray Substrate Readiness Check sheet
(Prior to vapour barrier Installation)**

Project Name: _____

Form Completed by: _____

Company: _____

Area ready: _____

Applicator _____

Dimond sheet installed with the narrow trough down

Fastening the metal tray sheet in the pan with 6 fasteners per purlin support.

If using timber supports, installed bitumen tape between timber and metal tray.

Confirm the substrate slope complies with specification.

Rainwater outlets and overflow recesses formed to fit outlets.

Ensure only approved accessories to be used for drainage.

Review penetrations to minimize number and complexity.

All edges of insulation supported by timber to prevent damage

Plinths formed for any exterior ventilation, fixtures or similar.

Substrate clean, firm and suitable condition for laying the Nuralite systems.

Notes _____

Signed by Applicator

Date: