

**Nuratherm Plywood Substrate Readiness Check sheet for Nuraply  
Everguard TPO  
(Prior to vapour barrier Installation)**

---

Project Name: \_\_\_\_\_  
Form Completed by: \_\_\_\_\_  
Company: \_\_\_\_\_  
Area ready: \_\_\_\_\_  
Applicator \_\_\_\_\_  
Fax Number: \_\_\_\_\_

- Structure complies with the New Zealand Building Code and plywood complies with AS/NZ 2269
- H3.2 CCA treated plywood sheets 17mm thick for roofs, 21mm thick for decks.
- Plywood sheets supported at 400mm centred rafters and noggs for roofs and decks. Unless otherwise specified.
- Sheets stagger lay (fully offset) with falls as per plan.
- 5mm clearances from all abutments, 5mm radius to all exposed edges.
- All sheet edges supported, fixed 150mm on edges and 200mm through girth, edges butt-jointed with no gaps except at abutments.
- Sheets fixed by gluing and Stainless Steel countersunk screw fixing.
- Mitres neatly formed.
- Rainwater outlets and overflow recesses formed to fit outlets rebated into the Surface.
- Sharp edges and lips removed and cavities filleted. All joints flush.
- Plinths formed for any exterior ventilation, solar panels or fixtures.
- Substrate dry, (less than 20% moisture), clean, firm and suitable condition for laying

*When substrate is ready complete this form and fax to the Nuralite applicator*

Notes

---

Signed by head contractor

Date: